# Change Proposal (Not a change order)

PROJECT:	Northeastern Vermont Regional Medical Center New MRI Addition St. Johnsbury, VT	CONTRACT NO. CHANGE PROPOSAL NO. DATE:	2533 006 18-Jun-19
Attached is an it	remized quotation for changes to the subject project sum an	d/or time as described herein.	
This document,	when fully executed, as accepted, shall constitute authoriza	tion to proceed with the work described herein.	
DESCRIPTION	OF PROPOSED CHANGE: Upgrade RF Shielding to	o accommodate a 3T unit	
Prov	vide & Install additional silicon steel at the rear wall and floo	Γ	\$3,313
		Sub Total	\$3,313
ATTACHMENTS	S: Email chain with ETS Lindgren	CM Fee @ 3.75% Change Proposal Total	\$124 <b>\$3,437</b>
	This Proposed Change Working Days Due To This Proposed Change	Add/Deduct 0 Days	\$3,437
The Amount Of	This Proposal Is Subject To Revision If Not Accepted In	10 Days	
H.P. CUMMING	S CONSTRUCTION COMPANY		
BY:	a Smith, Senior Project Manager		
	ENGINEER	OWNER Date:	18-Jun-19
	Recommend Acceptance	Accept	
	Do Not Recommend Acceptance	Do Not Accept	
BY:		BY:	
DAT	ΓΕ:	DATE:	



		3	
To:	Meagan Pennock	Date:	August 5, 2019
Address:		Project Number:	
		Project Name:	
		Project Location:	
		Change Order No.:	
		Requested by:	M. Pennock
Phone:		Phone:	
Email:		Email:	
We hereby agree to make the change(s) specified below:		Please check one of the following:	
,	3 ( ) 1	nternal	✓External
Quantity	Item	Unit Price	Price
1	Steel addition	3,313.00	3,313.00
ADDITION ORDER. NOTE: TH	INGN AND RETURN. FAILURE TO RESPOND WITHIN 10 BU AL COSTS TO BE INCURRED. ALL TAXES, WHERE APPLICATED IN CONFORM IN CONFORM IN CONFORM IN CONFORM IN CONFORM IN THE PROPERTY OF AND IN CONFORM IN THE PROPERTY	CABLE, ARE NOT INCL	JDED IN THIS CHANGE
Date:	,	Previous Contract	
ETS-Lindgren Manager's Approval:		Amount:	\$0.00
	- · · · · · · · · · · · · · · · · · · ·	Revised Contract	<b>\$0.00</b>
		Amount:	\$3,313.00
ACCEPTED - The above prices and specifications of this Change Notice are satisfactory and are hereby accepted. All work to be performed under the same terms and conditions as specified in original contract unless otherwise stipulated.		Date of acceptance: Signature:  (Owner/Contractor)	

# Meagan Pennock

From: Colin Clancy

**Sent:** Thursday, June 13, 2019 4:53 PM

**To:** Meagan Pennock

**Subject:** RE: NVRH - MRI - Siemens Action Items

It varies, depending on the location. Anywhere from 3/16, to ¼ inch

From: Meagan Pennock < mpennock@hpcummings.com>

Sent: Thursday, June 13, 2019 4:51 PM

**To:** Colin Clancy < Colin.Clancy@ets-lindgren.com > **Subject:** RE: NVRH - MRI - Siemens Action Items

What is the thickness of the silicon steel needed?

**From:** Colin Clancy < <a href="mailto:clancy@ets-lindgren.com">com</a>>

Sent: Thursday, June 13, 2019 4:49 PM

To: Meagan Pennock < <a href="mailto:mpennock@hpcummings.com">mpennock@hpcummings.com</a> Subject: RE: NVRH - MRI - Siemens Action Items

Only thing that needs to be changed is the addition of silicon steel in both the rear wall and floor.

Do the Siemens drawings convey enough for you to go back to NVRH?

From: Meagan Pennock < mpennock@hpcummings.com >

Sent: Thursday, June 13, 2019 4:48 PM

**To:** Colin Clancy < <a href="mailto:colin.clancy@ets-lindgren.com">colin.clancy@ets-lindgren.com</a> <a href="mailto:subject: RE: NVRH - MRI - Siemens Action Items">subject: RE: NVRH - MRI - Siemens Action Items</a>

Colin – when you're able can you get me something that shows what needs to be changed so I can try to explain it to NVRH?

## **Meagan Pennock**

# A. Project Manager

## **H.P. Cummings Construction Co.**

PO Box 269, 5 High St. Woodsville, NH 03785

T: 603-747-3303 ext. 109 | C: 603-991-3655 | E: mpennock@hpcummings.com |

Visit our Website at www.hpcummings.com



From: Meagan Pennock < mpennock@hpcummings.com >

Sent: Thursday, June 13, 2019 4:46 PM

**To:** 'Colin Clancy' < <u>Colin.Clancy@ets-lindgren.com</u>> **Subject:** RE: NVRH - MRI - Siemens Action Items

Appreciate it!

# **Meagan Pennock**

# A. Project Manager

## **H.P. Cummings Construction Co.**

PO Box 269, 5 High St. Woodsville, NH 03785

T: 603-747-3303 ext. 109 | C: 603-991-3655 | E: mpennock@hpcummings.com |

Visit our Website at www.hpcummings.com



From: Colin Clancy < <a href="mailto:Colin.Clancy@ets-lindgren.com">Colin.Clancy@ets-lindgren.com</a>>

Sent: Thursday, June 13, 2019 3:29 PM

**To:** Meagan Pennock < mpennock@hpcummings.com > **Subject:** RE: NVRH - MRI - Siemens Action Items

Based on the increase in silicon, its going to be an extra \$3,313

From: Meagan Pennock < mpennock@hpcummings.com >

**Sent:** Thursday, June 13, 2019 11:08 AM

**To:** Colin Clancy < <a href="mailto:colin.clancy@ets-lindgren.com">colin.clancy@ets-lindgren.com</a> <a href="mailto:subject: RE: NVRH - MRI - Siemens Action Items">https://doi.org/10.1001/

No I need an exact number as the hospital has to reply to the CON board. Get it to me tomorrow if you can please.

## **Meagan Pennock**

#### A. Project Manager

## **H.P. Cummings Construction Co.**

PO Box 269, 5 High St. Woodsville, NH 03785

T: 603-747-3303 ext. 109 | C: 603-991-3655 | E: mpennock@hpcummings.com |

Visit our Website at www.hpcummings.com



From: Colin Clancy < Colin. Clancy@ets-lindgren.com>

Sent: Thursday, June 13, 2019 10:22 AM

To: Meagan Pennock < mpennock@hpcummings.com > Subject: RE: NVRH - MRI - Siemens Action Items

Hi Meagan, apologies on the delay. Can you use an allowance of \$4,000 as a placeholder? I am traveling and likely will not be able to get this to you by EOB

From: Meagan Pennock < mpennock@hpcummings.com >

Sent: Thursday, June 13, 2019 10:20 AM

**To:** Colin Clancy < <u>Colin.Clancy@ets-lindgren.com</u>> **Subject:** RE: NVRH - MRI - Siemens Action Items

Colin – I need the pricing impacts to upgrade for the 3T requirements. Can you please get this to me today?

# **Meagan Pennock**

## A. Project Manager

# **H.P. Cummings Construction Co.**

PO Box 269, 5 High St. Woodsville, NH 03785

T: 603-747-3303 ext. 109 | C: 603-991-3655 | E: mpennock@hpcummings.com |

Visit our Website at www.hpcummings.com



From: Colin Clancy <Colin.Clancy@ets-lindgren.com>

**Sent:** Friday, May 31, 2019 9:17 AM

To: Meagan Pennock < <a href="mailto:mpennock@hpcummings.com">mpennock@hpcummings.com</a> Subject: RE: NVRH - MRI - Siemens Action Items

Has the hospital confirmed that they are upgrading the magnet to a 3T or is this still in discussion?

From: Meagan Pennock <mpennock@hpcummings.com>

**Sent:** Friday, May 31, 2019 9:11 AM

**To:** Colin Clancy < <a href="mailto:colin.clancy@ets-lindgren.com">colin.clancy@ets-lindgren.com</a> <a href="mailto:subject: RE: NVRH - MRI - Siemens Action Items">https://doi.org/10.1001/

Great thank you!

#### **Meagan Pennock**

#### A. Project Manager

**H.P. Cummings Construction Co.** 

PO Box 269, 5 High St. Woodsville, NH 03785

T: 603-747-3303 ext. 109 | C: 603-991-3655 | E: mpennock@hpcummings.com |

Visit our Website at www.hpcummings.com



From: Colin Clancy < <a href="mailto:Colin.Clancy@ets-lindgren.com">Colin.Clancy@ets-lindgren.com</a>>

**Sent:** Friday, May 31, 2019 9:11 AM

To: Meagan Pennock < mpennock@hpcummings.com >

Cc: Dominic Smith <domsmith@hpcummings.com>; Dan Smith <dsmith@hpcummings.com>

Subject: RE: NVRH - MRI - Siemens Action Items

Yes, early next week I will be able to give an updated price on the added silicon steel in the room.

From: Meagan Pennock < mpennock@hpcummings.com >

**Sent:** Friday, May 31, 2019 9:09 AM

To: Colin Clancy < Colin. Clancy@ets-lindgren.com>

Cc: Dominic Smith < domsmith@hpcummings.com >; Dan Smith < dsmith@hpcummings.com >

Subject: RE: NVRH - MRI - Siemens Action Items

Colin – are you able to put a price to that?

# **Meagan Pennock**

## A. Project Manager

# **H.P. Cummings Construction Co.**

PO Box 269, 5 High St. Woodsville, NH 03785

T: 603-747-3303 ext. 109 | C: 603-991-3655 | E: <u>mpennock@hpcummings.com</u> |

Visit our Website at www.hpcummings.com



From: Colin Clancy <Colin.Clancy@ets-lindgren.com>

**Sent:** Friday, May 31, 2019 9:01 AM

To: Meagan Pennock < mpennock@hpcummings.com >

Cc: Dominic Smith <domsmith@hpcummings.com>; Dan Smith <dsmith@hpcummings.com>

Subject: RE: NVRH - MRI - Siemens Action Items

Meagan,

In looking at the shielding design for the 3T, we would need to add additional silicon steel, per the requirements of Siemens.

From: Meagan Pennock <mpennock@hpcummings.com>

Sent: Thursday, May 30, 2019 4:03 PM

To: Colin Clancy < Colin.Clancy@ets-lindgren.com>

Cc: Dominic Smith <domsmith@hpcummings.com>; Dan Smith <dsmith@hpcummings.com>

Subject: FW: NVRH - MRI - Siemens Action Items

Importance: High

Hi Colin – NVRH would like to verify that the shielding being provide would be adequate incase they upgrade magnets. Can you please review the attached information from Siemens on the 3T unit and let me know?

Thanks,

## Meagan Pennock

# A. Project Manager

# **H.P. Cummings Construction Co.**

PO Box 269, 5 High St. Woodsville, NH 03785

T: 603-747-3303 ext. 109 | C: 603-991-3655 | E: mpennock@hpcummings.com |

Visit our Website at www.hpcummings.com



#### IMPORTANT NOTICE REGARDING THIS ELECTRONIC MESSAGE:

This message is intended for the use of the person to whom it is addressed and may contain information that is privileged, confidential, and protected from disclosure under applicable law. If you are not the intended recipient, your use of this message for any purpose is strictly prohibited. If you have received this communication in error, please delete the message and notify the sender so that we may correct our records.

#### IMPORTANT NOTICE REGARDING THIS ELECTRONIC MESSAGE:

This message is intended for the use of the person to whom it is addressed and may contain information that is privileged, confidential, and protected from disclosure under applicable law. If you are not the intended recipient, your use of this message for any purpose is strictly prohibited. If you have received this communication in error, please delete the message and notify the sender so that we may correct our records.

#### IMPORTANT NOTICE REGARDING THIS ELECTRONIC MESSAGE:

This message is intended for the use of the person to whom it is addressed and may contain information that is privileged, confidential, and protected from disclosure under applicable law. If you are not the intended recipient, your use of this message for any purpose is strictly prohibited. If you have received this communication in error, please delete the message and notify the sender so that we may correct our records.

#### IMPORTANT NOTICE REGARDING THIS ELECTRONIC MESSAGE:

This message is intended for the use of the person to whom it is addressed and may contain information that is privileged, confidential, and protected from disclosure under applicable law. If you are not the intended recipient, your use of this message for any purpose is strictly prohibited. If you have received this communication in error, please delete the message and notify the sender so that we may correct our records.