

From: Alexander J. LaRosa
Sent: Thursday, December 16, 2021 4:41 PM
To: Jerry, Donna
Subject: RE: Collaborative Surgery Center, GMCB-008-21con

The original single doors were 36", and the updated ones are 42". In other areas, there are a few uneven double leaf doors at 4'-6", and the main entry to the sterile area is a 8'-0" double door.

MSK Attorneys
275 College Street, P.O. Box 4485
Burlington, VT 05406-4485

From: Jerry, Donna
Sent: Wednesday, December 15, 2021 6:54 PM
To: Alexander J. LaRosa
Subject: Collaborative Surgery Center, GMCB-008-21con

Hi AJ. Based on the revised drawings you included in your response to Q003 and Q004, please confirm the original and revised dimensions of the main patient entry doors to the vestibule and the surgery center. Thank you in advance for confirming these dimensions.